



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215
March 4, 2005

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

Re: Ohio EPA Permit No. 2IN00004*HD
Application No. OH0002666
Facility: GM Powertrain Defiance Plant

General Motors Powertrain
Defiance Plant
PO Box 70
Defiance OH 43512


Ladies and Gentlemen:

We propose to make to following minor modification to the above referenced permit.

<u>Page</u>	<u>Correction</u>
6	Change measuring frequency from "1/Day" to "When Discharging for parameters: 00052 - Bypass Total Hours Per Day 00400 - pH 00610 - Nitrogen Ammonia 01094 - Zinc, Total Recoverable 01114 - Lead, Total Recoverable 01119 - Copper, Total Recoverable 50050 - Flow Rate 71901 - Mercury, Total Recoverable for final outfall 2IN00004002.

If you consent to this change, please sign below and incorporate the corrected page into your permit. The proposed minor modification will become effective on the date we receive this signed letter from you at the following address: Ohio Environmental Protection Agency, Division of Surface Water, Permit Administration Section, P. O. Box 1049, Columbus, Ohio 43266-0149.

Sincerely,


Patti L. Smith, Supervisor
Permit Processing Unit
Division of Surface Water

PLS/dks

Enclosure

CERTIFIED MAIL

I consent to the minor modification.

Name

Title

Date

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director

General

General Motors

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from outfall 2IN00004002**. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 002 - Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00052 - Bypass Total Hours Per Day - Hrs/Day	-	-	-	-	-	-	-	When Disch.	24hr Total	All
00400 - pH - S.U.	9	6.5	-	-	-	-	-	When Disch.	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	-	-	-	-	-	When Disch.	Grab	All
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	When Disch.	Grab	All
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	When Disch.	Grab	All
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	When Disch.	Grab	All
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	When Disch.	Grab	All
71901 - Mercury, Total Recoverable - ug/l	-	-	-	-	-	-	-	When Disch.	Grab	All

** In order for any discharge from this outfall to be authorized, the conditions of Part III Section 11 must be met.

Notes for Station Number 2IN00004002:

- Sampling shall be performed when discharging. If NO DISCHARGE OCCURS DURING THE ENTIRE MONTH, report "AL" in the first column of the first day of the month on the 4500 Form (Monthly Operating Report). A signature is still required.

- See Part IV, V and VI.

- See Part II, Item J.



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215
March 4, 2005

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

Re: Ohio EPA Permit No. 2IN00004*HD
Application No. OH0002666
Facility: GM Powertrain Defiance Plant

General Motors Powertrain
Defiance Plant
PO Box 70
Defiance OH 43512

Ladies and Gentlemen:

We propose to make to following minor modification to the above referenced permit.

Page	Correction
6	Change measuring frequency from "1/Day" to "When Discharging" for parameters: 00052 - Bypass Total Hours Per Day 00400 - pH 00610 - Nitrogen Ammonia 01094 - Zinc, Total Recoverable 01114 - Lead, Total Recoverable 01119 - Copper, Total Recoverable 50050 - Flow Rate 71901 - Mercury, Total Recoverable for final outfall 2IN00004002.

Q.52. 3/11/05

If you consent to this change, please sign below and incorporate the corrected page into your permit. The proposed minor modification will become effective on the date we receive this signed letter from you at the following address: Ohio Environmental Protection Agency, Division of Surface Water, Permit Administration Section, P. O. Box 1049, Columbus, Ohio 43266-0149.

Sincerely,

Patti L. Smith

Patti L. Smith, Supervisor
Permit Processing Unit
Division of Surface Water

PLS/dks

Enclosure

CERTIFIED MAIL

I consent to the minor modification.

Gay A. Monsen
Name

REGIONAL UTILITIES MANAGER
Title

3-17-05
Date

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director

RECEIVED

MAR 21 2005

Ohio Environmental Protection Agency